

APSTIPRINU
AS „Rēzeknes Siltumtīkli”
valdes loceklis

A.Mežals

2012.g. „ ”

TEMPERATŪRAS GRAFIKS
siltuma padevei no katlu mājām
N.Rancāna ielā 5, Atbrīvošanas alejā 155A

Ārējā gaisa temperatūra, °C	Turpgaitas ūdens temperatūra, °C	Atpakaļgaitas ūdens temperatūra, °C
+ 10	65	42
+ 9	65	42
+ 8	65	42
+ 7	65	42
+ 6	65	42
+ 5	65	42
+ 4	65	42
+ 3	65	42
+ 2	65	42
+ 1	67	43
0	69	44
- 1	71	45
- 2	73	46
- 3	74	47
- 4	76	48
- 5	78	49
- 6	80	50
- 7	82	51
- 8	83	52
- 9	85	53
- 10	87	54
- 11	89	55
- 12	90	56
- 13	92	57
- 14	94	58
- 15	96	59
- 16	97	60
- 17	99	61
- 18	101	62
- 19	103	63
- 20	104	64
- 21	106	65
- 22	108	66
- 23	110	67
- 24	112	68
- 25	114	69
- 26	115	70